



# 1800 Series SC Accessory Data Sheet

Customer-Specified Display Settings

- The 1800 Series SC accessory is used to have the device's settings be pre-programmed before the unit ships. Below are the device settings with the available options.
- A completed form is required at time of order if the model number includes the SC accessory. Please use the drop-downs to choose the desired option or enter the desired value; any setting left blank will be set to the default value.

Setting	Desc.	Default Value	Desired Value
<b>Display Mode</b>	The display mode determines what is shown when the device is in the measuring interface.	Process Variable (Pressure)	Select Mode
<b>Unit of Measure</b>		Either kPa or MPa (range dependent)	Select Unit of Measure
<b>4mA &amp; 20mA Pressure Settings</b>	Specify using the unit of measure selected for 2.	4mA = Lower Range Value 20mA = Upper Range Value	4mA Pressure Setting
			20mA Pressure Setting
<b>Damping Time</b>	The damping time can be set from 0 to 100 seconds.	0 seconds	Time
<b>Output Signal Type</b>		Linear	Select Signal Type
<b>Fault Alarm Signal</b>		None	Select Alarm Signal



**1800PT**  
Standard  
Over Pressure



**1800HP**  
High  
Over Pressure



**1800DP**  
Differential  
Pressure

For SOR  
Internal Use Only

Customer Order # \_\_\_\_\_

Line(s) \_\_\_\_\_